

NECESSARY DETAILS

SL	Name of Item and Specification	Unit	Qty	Single Rate (Tk)	Total Amount (Tk)	Remarks
a	(b)	(c)	(d)	(e)	(f)	(g)
1.	Thermal Imaging Scanner with all standard and additional accessories as per specification bellow. Specification : Brand : Fluke/UNI-T/Stanlay, Model: Tis20 or Equivalent IR resolution: 120 x 90 (10,800 pixels) Country of Origin: Group - A	No	1			
2.	Digital Megger with all standard and additional accessories as per specification bellow. Specification : Brand : Megger /Fluke/Stanlay , Model: MIT1025 or Equivalent Testing Voltage: 250 V, 500 V, 1000 V, 2500 V, 5000 V,10000V Accuracy Class: $\pm 5\%$ from 1M Ω to 2 T Ω ; $\pm 20\%$ from 1M Ω to 20 T Ω , Country of Origin: Group - A	No	1			
3.	Digital Underground Cable fault distance locator with all standard and additional accessories as per specification bellow. Specification : Brand : XZH Test/Megger /Fluke/UNI-T/Stanlay Model: XAHGG502/XHDD503D or Equivalent The longest testing distance: 32KM (100KM for the open-wire line) Power Supply: AC or DC power supply inside machine; AC 220V $\pm 10\%$, Country of Origin: Any Country	No	1			
4.	Earth Clamp Tester with all standard and additional accessories as per specification bellow. Specification : Brand : KYORITSU/ Fluke/UNI-T/Stanlay Model: kew 4200 or Equivalent AC Current Auto Range (50Hz/60Hz): 100mA, 1000mA, 10A, 830A, Country of Origin: Group - A	No	1			
5.	Analog Multimeter, Brand: Sanwa, Model: YX361TR Country of Origin: Group – A	No	1			
6.	Digital Earth Tester with all standard and additional accessories as per specification bellow. Specification : Brand : KYORITSU/Fluke/UNI-T/Stanlay Model: kyoritsu 4105A-H or Equivalent Country of Origin: Group - A	No	1			
7.	Digital Microscope 8 inch Display with stand Total magnification : 11X ~ 102X Zoom Objective : 0.65X – 6X, ratio 1:9 CCD Camera : 1/3" CCD, 580 TVL, with built in 0.5X reduction LCD monitor : 8", with reticle, adjustable brightness and contrast, PC/AV input, Country of Origin: Group - A	No	1			

Terms & Conditions:

- Installation, trial run & local training (both Operation and Maintenance) should be done by the supplier at BOF site.
- Warranty: Minimum 1 (One) year after acceptance at BOF.
- Warranty card and standard operating procedure (SOP) from authorized dealer/machine manufacturer need to be provided with the items.
- Quality assurance certificate (QAC) & calibration certificate original copy signed by appropriate authority of manufacturer Quality Control Department should be provided with the Items.
- Other related accessories for operating the instrument need to be provided with the items.

বিঃ দ্রঃ

- ক। উল্লেখিত দর CD & VAT ব্যতীত দাখিল করতে হবে। প্রয়োজনবোধে পণ্য খালাসের জন্য বিওএফ এর নিকট ছাড়পত্রের আবেদন করা যাবে।
- খ। বৈদেশিক উৎস হতে পণ্য সরবরাহের ক্ষেত্রে পণ্য সরবরাহের প্রাক্কালে অবশ্যই আমদানী সংক্রান্ত কাগজপত্র, বিল অব লেডিং, শিপিং ডকুমেন্টস প্রদান করতে হবে।
- গ। টেকনিক্যাল এবং ফিন্যান্সিয়াল অফার একই খামে দাখিল করতে হবে।
- ঘ। পণ্যের উৎস দেশ উল্লেখ না থাকলে কিংবা একাধিক উৎস দেশের বেলায় মূল্যোদ্ধতি প্রদান কালে অবশ্যই নির্দিষ্ট করে উৎস দেশ উল্লেখ করতে হবে।
- ঙ। দেশীয় মুদ্রায় ক্রয়ের ক্ষেত্রে স্থানীয় উৎস হতে সরবরাহের ক্ষেত্রে ৯০ দিন এবং বৈদেশিক উৎস হতে সরবরাহের ক্ষেত্রে ১৮০ দিন অথবা তৎপূর্বে পণ্য সরবরাহ করতে হবে।
- চ। সরবরাহ আদেশের বিপরীতে সরবরাহকৃত পণ্য প্রত্যাখাত হলে প্রতিস্থাপনের বেলায় পণ্যের পুনঃ পরীক্ষার ক্ষেত্রে প্রতিবারের জন্য প্রচলিত হারে চার্জ প্রদান করতে হবে।
- ছ। সরবরাহ আদেশ প্রদানের প্রাক্কালে মোট মূল্যের উপর ৫% হারে কমান্ড্যান্ট, বিওএফ গাজীপুর ক্যান্ট এর অনুকূলে পিএস (পে-অর্ডার) দাখিল করতে হবে। সন্তোষজনকভাবে পণ্য সরবরাহ হওয়ার এবং পরিদর্শনে গৃহীত হওয়ার পর উক্ত পে-অর্ডার ফেরৎ প্রদান করা হবে। পণ্য সরবরাহে ব্যর্থতায় দাখিলকৃত পে-অর্ডার বাতিল পূর্বক উক্ত অর্থ সরকারী কোষাগারে জমা করা হবে।
- জ। দেশীয় মুদ্রায় বিল পরিশোধের সময় প্রযোজ্য ক্ষেত্রে ভ্যাট ও আয়কর কর্তন করা হবে।
- ঝ। নিম্নলিখিত সনদপত্রের ফটোকপি দরপত্রের সাথে অবশ্যই সংযুক্ত করতে হবেঃ

১। ভ্যাট রেজিস্ট্রেশন সনদ

২। টি আই এন সনদ

৩। হালনাগাদ ট্রেড লাইসেন্স

স্থান :

তারিখ :

দরপত্রে অংশগ্রহণকারীর স্বাক্ষর

(বড় অক্ষরে নাম)

‘সীলমোহর’